



Product Approval

USER: Public User

[Product Approval Menu](#) > [Product or Application Search](#) > [Application List](#) > **Application Detail**

- ▶ COMMUNITY PLANNING
- ▶ HOUSING & COMMUNITY DEVELOPMENT
- ▶ EMERGENCY MANAGEMENT
- ▶ OFFICE OF THE SECRETARY

FL #	FL3901-R3
Application Type	Revision
Code Version	2007
Application Status	Approved
Comments	
Archived	
Product Manufacturer	TAMKO Building Products, Inc.
Address/Phone/Email	PO Box 1404 Joplin, MO 64802 (800) 641-4691 Ext 2394 fred_oconnor@tamko.com
Authorized Signature	Kerri Eden kerri_eden@tamko.com
Technical Representative	Frederick J. O'Connor
Address/Phone/Email	PO Box 1404 Joplin, MO 64802 (800) 641-4691 fred_oconnor@tamko.com
Quality Assurance Representative	
Address/Phone/Email	
Category	Roofing
Subcategory	Metal Roofing
Compliance Method	Evaluation Report from a Product Evaluation Entity
Evaluation Entity	ICC Evaluation Service, Inc.
Quality Assurance Entity	Underwriters Laboratories Inc.
Quality Assurance Contract Expiration Date	07/16/2010
Validated By	Robert J. M. Nieminen, PE Validation Checklist - Hardcopy Received
Certificate of Independence	FL3901_R3_COI_Florida_Certification.pdf
Referenced Standard and Year (of Standard)	Standard ASTM A 653 G-90
	Year 2004
Equivalence of Product Standards Certified By	

Sections from the Code

Product Approval Method Method 1 Option C

Date Submitted 08/12/2008
 Date Validated 09/08/2008
 Date Pending FBC Approval 09/15/2008
 Date Approved 10/14/2008

Summary of Products		
FL #	Model, Number or Name	Description
3901.1	Astonwood Steel Shingles	Steel shingles that simulate the look of real wood shingles.
Limits of Use Approved for use in HVHZ: No Approved for use outside HVHZ: Yes Impact Resistant: N/A Design Pressure: N/A Other: Not approved for use in High Velocity Hurricane Zones. Minimum slope 4:12. Not approved for jurisdictions with a rain fall rate greater than 8.8 in/hour and a wind velocity greater than 100 mph.		Installation Instructions FL3901_R3_II_mw_app_ins.pdf Verified By: ICC Evaluation Service, Inc. Created by Independent Third Party: Evaluation Reports FL3901_R3_AE_ESR-1129.pdf
3901.2	Stonecrest Slate Steel Shingles	Steel shingles that simulate the look of natural slate.
Limits of Use Approved for use in HVHZ: No Approved for use outside HVHZ: Yes Impact Resistant: N/A Design Pressure: N/A Other: Not approved for use in High Velocity Hurricane Zones. Minimum slope 4:12. Not approved for jurisdictions with a rain fall rate greater than 8.8 in/hour and a wind velocity greater than 100 mph.		Installation Instructions FL3901_R3_II_mw_app_ins.pdf Verified By: ICC Evaluation Service, Inc. Created by Independent Third Party: Evaluation Reports FL3901_R3_AE_ESR-1129.pdf
3901.3	Stonecrest Tile Steel Shingles	Steel shingles that simulate the look of uniform tile.
Limits of Use Approved for use in HVHZ: No Approved for use outside HVHZ: Yes Impact Resistant: N/A Design Pressure: N/A Other: Not approved for use in High Velocity Hurricane Zones. Minimum slope 4:12. Not approved for jurisdictions with a rain fall rate greater than 8.8 in/hour and a wind velocity greater than 100 mph.		Installation Instructions FL3901_R3_II_mw_app_ins.pdf Verified By: ICC Evaluation Service, Inc. Created by Independent Third Party: Evaluation Reports FL3901_R3_AE_ESR-1129.pdf

[Back](#) [Next](#)

DCA Administration
 Department of Community Affairs
 Florida Building Code Online
 Codes and Standards
 2555 Shumard Oak Boulevard
 Tallahassee, Florida 32399-2100
 (850) 487-1824, Fax (850) 414-8436

© 2000-2005 The State of Florida. All rights reserved. [Copyright and Disclaimer](#)

Product Approval Accepts:

