



**BUILDING CODE COMPLIANCE OFFICE (BCCO)  
PRODUCT CONTROL DIVISION**

**MIAMI-DADE COUNTY, FLORIDA  
METRO-DADE FLAGLER BUILDING  
140 WEST FLAGLER STREET, SUITE 1603  
MIAMI, FLORIDA 33130-1563  
(305) 375-2901 FAX (305) 375-2908**

**NOTICE OF ACCEPTANCE (NOA)**

**Tamko Building Products, Inc.  
P.O. Box 1404  
Joplin, MO 64802**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

**DESCRIPTION: TAMKO Heritage 30 AR, Heritage XL AR & Heritage 50 AR Roof Shingles**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This revises NOA 07-0924.14 and consists of pages 1 through 5.  
The submitted documentation was reviewed by Alex Tigera.



**NOA No.: 08-0514.08  
Expiration Date: 12/01/10  
Approval Date: 07/10/08  
Page 1 of 5**

# ROOFING SYSTEM APPROVAL

**Category:** Roofing  
**Sub-Category:** 07310 Asphalt Shingles  
**Materials:** Dimensional  
**Deck Type:** Wood

## 1. SCOPE

This approves **Tamko Heritage 30 AR, Heritage XL AR and Heritage 50 AR** Asphalt Shingles, manufactured by **Tamko Building Products, Inc.** as described in this Notice of Acceptance.

## 2. PRODUCT DESCRIPTION

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Heritage 30 AR	13¼" x 38¾"	TAS 110	A heavy weight, dimensional asphalt shingle.
Heritage XL AR	13¼" x 39¾"	TAS 110	A heavy weight, dimensional asphalt shingle
Heritage 50 AR	13¼" x 39¾"	TAS 110	A heavy weight, dimensional asphalt shingle.

## 3. EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Underwriters Laboratories, Inc.	TAS 107	04CA44252	02/25/05
	ASTM D3462	02NK33813 03CA14536	09/23/02 01/15/04
PRI Asphalt Technologies, Inc.	TAS 100	TAP-129-02-01	05/23/05
		TAP-130-02-01	05/20/05
		TAP-131-02-01	05/20/05

## 4. LIMITATIONS

- 4.1 Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
- 4.2 Shall not be installed on roof mean heights in excess of 33 ft.
- 4.3 All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

## 5. INSTALLATION

- 5.1 Shingles shall be installed in compliance with Roofing Application Standard RAS 115.
- 5.2 The manufacturer shall provide clearly written application instructions.
- 5.3 Exposure and course layout shall be in compliance with Detail 'A', attached.
- 5.4 Nailing shall be in compliance with Detail 'B', attached.



NOA No.: 08-0514.08  
 Expiration Date: 12/01/10  
 Approval Date: 07/10/08  
 Page 2 of 5

**6. LABELING**

**6.1** Shingles shall be labeled with the Miami-Dade Seal as seen below or the wording "Miami-Dade County Product Control Approved".



**7. BUILDING PERMIT REQUIREMENTS**

**7.1** Application for building permit shall be accompanied by copies of the following:

**7.1.1** This Notice of Acceptance.

**7.1.2** Any other documents required by the Building Official or the applicable code in order to properly evaluate the installation of this system.

**8. MANUFACTURING PLANTS**

**8.1 Dallas Plant**  
7910 S. Central Expressway  
Dallas, TX. 75216


**8.2 Tuscaloosa, AL Plant**  
2300 35<sup>th</sup> Street Kaul Ind. Park  
Tuscaloosa, AL. 35401



### DETAIL A


### HERITAGE 30 AR

All dimensions are in inches.



### HERITAGE XL AR & HERITAGE 50 AR

All dimensions are in inches.




## DETAIL B

### HERITAGE 30 AR

13-1/4" x 38-3/4" LAMINATED SHINGLE


All dimensions are in inches.



### HERITAGE XL AR & 50 AR

13-1/4" x 39-3/8" LAMINATED SHINGLE

All dimensions are in inches.



**END OF THIS ACCEPTANCE**



NOA No.: 08-0514.08  
Expiration Date: 12/01/10  
Approval Date: 07/10/08  
Page 5 of 5